



1990 Prospect Ct., Appleton, WI 54914 * 800-801-7590

TODD HANSON
 SPARTA WATER UTILITY
 201 W OAK ST
 SPARTA, WI 54656

Home Owner SPARTA WATERWORKS
 Well ID/Address 1127 N CHESTER ST
 Well City SPARTA WI
 Sample Location SAMPLE TAP
 Lab # 608390
 Collected By/Date S PETERSON 01/16/2023

Report Date 31-Jan-23

Analyte	Result	Units	LOD	LOQ	Dil	Dig	Date	Run Date	Mthd	Analyst	QC Code
PFAOS											
PFOS	None Detected	ng/L	2	2	1		01/19/2023	01/19/2023	PFAOS	MR	1
PFBS	None Detected	ng/L	2	2	1		01/19/2023	01/19/2023	PFAOS	MR	1
PFHpA	None Detected	ng/L	2	2	1		01/19/2023	01/19/2023	PFAOS	MR	1
PFOA	None Detected	ng/L	2	2	1		01/19/2023	01/19/2023	PFAOS	MR	1
PFHxS	None Detected	ng/L	2	2	1		01/19/2023	01/19/2023	PFAOS	MR	1
PFNA	None Detected	ng/L	2	2	1		01/19/2023	01/19/2023	PFAOS	MR	1
PFDA	None Detected	ng/L	2	2	1		01/19/2023	01/19/2023	PFAOS	MR	1
PFHxA	None Detected	ng/L	2	2	1		01/19/2023	01/19/2023	PFAOS	MR	1
EtFOSAA	None Detected	ng/L	2	2	1		01/19/2023	01/19/2023	PFAOS	MR	1
HFPO-DA	None Detected	ng/L	2	2	1		01/19/2023	01/19/2023	PFAOS	MR	1
PFUnDA	None Detected	ng/L	2	2	1		01/19/2023	01/19/2023	PFAOS	MR	1
PFDoDA	None Detected	ng/L	2	2	1		01/19/2023	01/19/2023	PFAOS	MR	1
PFTTrDA	None Detected	ng/L	2	2	1		01/19/2023	01/19/2023	PFAOS	MR	1
PFTeDA	None Detected	ng/L	2	2	1		01/19/2023	01/19/2023	PFAOS	MR	1
11CI-PF3OUdS	None Detected	ng/L	2	2	1		01/19/2023	01/19/2023	PFAOS	MR	1
9CI-PF3ONS	None Detected	ng/L	2	2	1		01/19/2023	01/19/2023	PFAOS	MR	1
ADONA	None Detected	ng/L	2	2	1		01/19/2023	01/19/2023	PFAOS	MR	1
N-MeFOSAA	None Detected	ng/L	2	2	1		01/19/2023	01/19/2023	PFAOS	MR	1

LOD Limit of Detection

None Detected = Result was less than the LOD

LOQ Limit of Quantitation

Code

Comment

1

All laboratory QC requirements were met for this sample.

MRT denotes sub contract lab - Certification #399147320

Laboratory Director

Please visit our website at www.cleanwatertesting.com

WI DNR Lab Certification # 445126660

EPA ID# WI 00063

WI Dept of Ag Lab ID # 152673-D3

Page 1 of 1